


# CERTIFICATE OF CONFORMITY



Issued to: Altenergy Power System Inc.  
No.1, Yatai Road, Jiaxing 314050 Zhejiang Province, P.R. China

For the product: 3-phase Microinverter

Trade name:  **APsystems**  
ALTENERGY POWER

Type/Model: QT2, QT2-EU

Ratings: Operating temperature range: - 40°C to + 65°C  
Protective class: I  
Ingress protection rating: IP67  
Power factor range (adjustable): 0.8 leading...0.8 lagging  
PV input: max. 60 Vdc, MPPT voltage range: 28-45 Vdc, max 20 A x 4,  
Isc PV: 25 A x 4  
AC output: 400 Vac, 50 Hz, rated apparent power 2000VA, max 2.9A x 3

Manufactured by: Altenergy Power System Inc.  
No.1, Yatai Road, Jiaxing 314050 Zhejiang Province, P.R. China

Requirements: EN 50549-1:2019  
COMMISSION REGULATION (EU) 2016/631 (NC RfG)


This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6125985.50

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The certificate does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 6 June 2022  
It expires at the latest on: 6 June 2027

Certificate no: 6125985.01COC

DEKRA Testing and Certification (Shanghai) Ltd.

  
Cliff Lin  
Certification Manager

© Integral publication of this certification and adjoining reports is allowed

Accreditation of the certification body by IAS according to ISO/IEC 17065 for products.  
Accreditation is valid in the areas of certification mentioned in the certificate.

DEKRA Testing and Certification (Shanghai) Ltd.  
3F #250 Jiangchangsan Road Shibe Hi-Tech Park, 200436 Jing'an District, Shanghai, China  
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-product-safety.com

ESA-CER-F013 v1.4

