User Manual

Lithium Battery Pack

Soluna 10K Pack HV (L-E)

Feb.2023 Revision A.5

About this manual

This manual describes how to install the Soluna 10K Pack HV (L-E) battery. Please read this manual carefully before you start to install the product, and follow the instructions throughout the installation process. If you are not sure about any of the requirements, recommendations, or safety procedures described in this manual, please contact Soluna immediately for advice and clarification. The information included in this manual is accurate at the time of publication. However, with regards to the product design and technical specification updates, our company reserves the right to make changes at any time without prior notice. In addition, the illustrations in this manual are meant to help explain system configuration concepts and installation instructions. The illustrated items maybe different from the actual items at the installation location.

Content		
1 Safety precautions	4	
1.1 Warning Sign	4	
1.2 Safety instructions	4	
1.2.1 Risks of explosion	5	
1.2.2 Risks of fire	5	
1.2.3 Risks of electric shock	5	
1.2.4 Risks of damage to the battery pack	5	
1.3 Battery handling guide	5	
1.4 Response to emergency situations	6	
1.4.1 Leaking batteries	6	
1.4.2 Inhalation	6	
1.4.3 Eye contact	6	
1.4.4 Skin contact	6	
1.4.5 Ingestion	6	
1.4.6 Fire	6	
1.4.7 Wet batteries	7	
1.4.8 Damaged batteries	7	
1.5 Qualified installers	7	
2 Product Introduction	8	
2.1 Features	8	
2.2 Application	8	
2.3 Outline Dimension	9	
2.4 Technical data	10	
2.5 Appearance	12	
2.6 Connection port	13	
2.7 CAN communication interface definition (CAN1 & CAN2)	14	
3 Installation	15	
3.1Unpacking the package	15	
3.2 Packing lists	16	
3.3 Installation materials	16	
3.4 Installation location	16	
3.6 Installation requirement	18	
3.7 Safety gear	19	
3.8 Wiring specification	19	
3.9 Wi-Fi module connection	20	
4 Electrical connection	21	
4.1 Single battery unit	21	
4.2 The battery units are connected in parallel	21	
5 How to operate Soluna 10K Pack HV (L-E)	23	
6 LED indicator description	24	
7 Trouble shooting guideline	25	
8 DOD setting of Inverter	27	
9 Contact us	27	

1 Safety precautions

1.1 Warning Sign

Warning signs are used to warn you about the conditions that may cause severe injury or damage to the device. They instruct you to exercise caution to prevent danger. The following table describes the warning signs used in this manual.

Sign	Description
4	This battery pack contains high voltage which can cause electric shock resulting in severe injury.
+-	Make sure that the battery polarity is connected correctly.
	Keep the battery pack away from open flame or ignition sources
	Keep the battery pack away from children.
	Read the manual before installing and operating the battery pack.
	The battery pack is heavy enough to cause severe injury
	The battery pack may leak corrosive electrolyte.
	The battery pack may explode.
	The battery pack should not be disposed with household waste at the end of its working life.
\wedge	Physical injury or damage to the devices may occur if related requirements are not followed.

1.2 Safety instructions

For safety reasons, installers are responsible for familiarizing themselves with the contents of this manual and all warnings before performing installation.

General safety precautions



Failure to observe the precautions described in this section can cause serious injury to persons or damage to property, observe the following precautions.

1.2.1 Risks of explosion

- Do not subject the battery pack to strong impacts.
- Do not crush or puncture the battery pack.
- •Do not dispose of the battery pack in a fire.

1.2.2 Risks of fire

- Do not expose the battery pack to temperatures in excess of 60°C.
- •Do not place the battery pack near a heat source, such as a fireplace.
- Do not expose the battery pack to direct sunlight.
- Do not allow the battery connectors to touch conductive objects such as wires.

1.2.3 Risks of electric shock

- Do not disassemble the battery pack.
- Do not touch the battery pack with wet hands.
- Do not expose the battery pack to moisture or liquids.
- Keep the battery pack away from children and animals.

1.2.4 Risks of damage to the battery pack

•Do not allow the battery pack to come in contact with liquids.

- Do not subject the battery pack to high pressures.
- Do not place any objects on top of the battery pack.

1.3 Battery handling guide

- Use the battery pack only as directed.
- Do not use the battery pack if it is defective, appears cracked, broken or otherwise damaged, or fails to operate .
- Do not attempt to open, disassemble, repair, tamper with, or modify the battery pack. The battery pack is not user serviceable.
- To protect the battery pack and its components from damage when transportation, handle with care.

- Do not impact, pull, drag or step on the battery pack.
- Do not subject it to any strong force.
- Do not insert foreign objects into any part of the battery pack.
- Do not use cleaning solvents to clean the battery pack.

1.4 Response to emergency situations

The Soluna 10K Pack HV (L-E) battery pack comprises multiple batteries that are designed to prevent hazards resulting from failures. However, Soluna cannot guarantee their absolute safety.

1.4.1 Leaking batteries

If the battery pack leaks electrolyte, avoid contact with the leaking liquid or gas. the electrolyte is corrosive and contact may cause skin irritation and chemical burns. If someone is exposed to the leaked substance, do these actions:

1.4.2 Inhalation

Evacuate the contaminated area, and seek medical attention immediately.

1.4.3 Eye contact

Rinse eyes with flowing water for 15 minutes, and seek medical attention immediately.

1.4.4 Skin contact

Wash the affected area thoroughly with soap and water, and seek medical attention immediately.

1.4.5 Ingestion

Induce vomiting, and seek medical attention immediately.

1.4.6 Fire

In case there is a fire, always have an ABC or carbon dioxide extinguisher.



The battery pack may catch fire when heated above 150°C. If a fire breaks out where the battery pack is installed, do these actions:

- Extinguish the fire before the battery pack catches fire.
- If it is impossible to extinguish the fire but you have time, move the battery pack to a safe area before it catches fire.
- If the battery pack has caught fire, do not try to extinguish it. Evacuate people immediately.



If the battery catches fire, it will produce noxious and poisonous gases. Do not approach.

1.4.7 Wet batteries

If the battery pack is wet or submerged in water, do not try to access it. Contact Soluna or your distributor for technical assistance.

1.4.8 Damaged batteries

Damaged batteries are dangerous and must be handled with extreme caution. They are not fit for use and may pose a danger to people or property.

If the battery pack seems to be damaged, pack it in its original container, and then return it to Soluna or your distributor.



Damaged batteries may leak electrolyte or produce flammable gas. If you suspect such damage, immediately contact Soluna for advice and information.

1.5 Qualified installers

This manual and the tasks and procedures described herein are intended for use by skilled workers only. A skilled worker is defined as a trained and qualified electrician or installer who has all of the following skills and experience:

- Knowledge of the functional principles and operation of on-grid systems.
- Knowledge of the dangers and risks associated with installing and using electrical devices and acceptable mitigation methods.
- Knowledge of the installation of electrical devices.
- Knowledge of and adherence to this manual and all safety precautions and best practices.

2 Product Introduction

Soluna 10K Pack HV (L-E) is a LFP lithium battery product with BMS (battery management system). It is a high-voltage battery module with CAN communication, under-voltage,over-voltage,over-current,over-temperature,under-temperature protection functions. It has the characteristics of high energy density, long life, safety and reliability and so on, and It is your trustworthy green environmental product.

2.1 Features

- Excellent safety performance
- Long cycle life
- Support for CAN-communication
- High energy density
- Excellent battery management system
- Number of expandable battery units
- Wi-Fi monitor

2.2 Application

- Back-up power
- Micro-grid
- Home Energy Storage system

2.3 Outline Dimension



Width	654	mm
Depth	227	mm
Height	971	mm
Weight	105	kg

2.4 Technical data

Physical Characteristics

Width	654mm
Depth	227mm
Height	971mm
Weight	105kg

Electrical Characteristics

Battery type	LFP
Total Energy Capacity	10kWh
Usable Energy Capacity	9kWh
Battery Capacity (Nominal)	40Ah
Voltage Range (Usable)	235.2~294V
Nominal Voltage	268.8V
Charge voltage (CV)	294V
Discharge cut-off voltage	235.2V
Charge/Discharge Current (Nominal)	20A/20A
Charge/Discharge Current (Max)	40A/40A
DOD	90%
Cycle life @ 25℃	
(under standard charge and discharge	≥6000
conditions, charge 0.2C, discharge 0.2C)	
DC Disconnect	Contactor
	Fuse
Number of expandable battery units	10

BMS

Power consumption	≤100mA (work),		
Fower consumption	≤0.1mA (sleep)		
Monitoring parameters	System Voltage		
	System Current		
	Cell Voltage		
	Cell temperature		
Communication	CAN		

Operating Conditions

Condition	Indoor conditioned
Operating Temperature	-10~50 ℃
Operating Temperature (Recommended)	15~30 ℃
Storage Temperature	-30~60 °C

Humidity	5%~95%
Altitude	Max. 2,000 m
Cooling Strategy	Natural Convection

Reliability & Certification

Cartificates	Cell: UL1642		
Certificates	Battery Module: IEC62619 & UL1973		
Transportation	UN38.3		
Ingress Rating	IP54		

Warranty

Please refer to SOLUNA WARRANTY CONDITIONS

2.5 Appearance



Number	Name	Remark
1	Cable connection interface	
2	Power ON/OFF switch	
34	Handle	
56	Grounding points	
7	Status indicator light	
8	Bracket attached to wall	

2.6 Connection port

User can see the connections port of Soluna 10K Pack HV (L-E) after the cover cap opened, please see the below picture in details.



Number	Name	Remark
	CAN1 port	For external communication (inverter)
2	CAN2 port	For internal communication (BMS)
3	Battery+	
4	Battery-	

2.7 CAN communication interface definition (CAN1 & CAN2)



2.7.1 CAN1 port (for inverter communication)

1	2	3	4	5	6	7	8
_			CAN1H	CAN1L			_

2.7.1 CAN2 port (for battery communication)

1	2	3	4	5	6	7	8
485A	485B	GND	CAN1H	CAN1L	+12V	CAN2H	CAN2L

3 Installation



The battery pack is too heavy for one to carry. Make sure that two or more persons are moving the battery pack together.

3.1Unpacking the package

3.1.1 Please see the packaging of Soluna 10K Pack HV(L-E) below.



- Remark:Users can scan the QR code on the package to obtain the electronic user Manual.
- 3.1.2 Open the packing box, take out the wall bracket and remove the EPE plate.



Number	Name	Remark
1	EPE plate	
2	Wall bracket	
3	Soluna 10K Pack HV (L-E)	

- 3.1.3 Pull out the battery pack and stand it upright. Check if the battery pack is damaged.
- 3.1.4 All the other items are contained in a box in one corner of the carton. Take them out and check if any item is missing
- 3.1.5 Keep the carton for future storage or transportation

3.2 Packing lists

The following table lists the numbers of each item included. If anything is damaged or missing, contact Soluna or your distributor.

Item	Name	Qty (pcs)	Remark
1	Soluna 10K Pack HV (L-E)	1	
2	PE wire	1	
3	Allen wrench (M2.5)	1	
4	M4 socket head combination screws	4	
5	M6 Phillips head three combination screw	10	
6	M8 expansion screw combination	8	
7	Wall bracket	1	
8	CAN communication wire	1	

3.3 Installation materials

These installation materials shall be prepared by installers.

- Charging cables
- Network cables
- DC breaker

3.4 Installation location

Please make sure that the installation location meets the following conditions:

- The building is designed to withstand earthquakes.
- The location is far away from the sea, to avoid salt water and humidity.
- The floor is flat and level.
- There are no flammable or explosive materials nearby.
- The ambient temperature is between 15 and 30°C.
- The temperature and humidity stays at a constant level.
- There is minimal dust and dirt in the area.
- There are no corrosive gases present, including ammonia and acid vapor.



If the ambient temperature is outside the operating range, the battery pack stops operating to protect itself. The optimal temperature range for the battery pack to operate is 15°C to 30°C. Frequent exposure to harsh temperatures may deteriorate the performance and lifetime of the battery pack.

3.5 Installation tools

The following tools are required to install the battery pack.

Item	Photo	Name
1		Phillips-screwdriver bit
2	Contraction of the second seco	Network crimper
3		Wire cutters
4		Wire stripper
5		Tape measure

Use properly insulated tools to prevent accidental electric shock or short circuits. Use adjustable tools and measuring instruments that are certified for precision and accuracy.

3.6 Installation requirement

Soluna 10K Pack HV (L-E) should be installed attached the wall, Eight holes should be drilled on the wall in order to fix the racks of the battery module. Please find the following pictures for details.



3.7 Safety gear

Wear the following safety gear when dealing with the battery pack. Installers must meet the relevant requirements of international standards, such as IEC 60364, or the domestic legislation.

ltem	Photo	Name
1	(All)	Insulated gloves
2		Safety goggles
3		Safety shoes

3.8 Wiring specification

In order to standardize the wiring specification of Soluna 10K Pack HV (L-E), the following requirements are required for connecting wires of Soluna 10K Pack HV (L-E).

Battery cable	Communication cable
It is recommended to use 8AWG of	It is recommended to use Standard
conductor with double insulation	communication cable with shielding
	function

3.9 Wi-Fi module connection

3.9.1 Single battery unit

Wi-Fi module should be connected to the CAN2 port of battery with Wi-Fi cable, Please find the following position of Wi-Fi module for details.

Wi-Fi installation position



3.9.2 The battery units are connected in parallel

User only need to install 1 unit Wi-Fi module on the HV parallel box, Please find the following position of Wi-Fi module for details.



Remark:

1) User can find the user manual of Wi-Fi module in the Wi-Fi packing box

4 Electrical connection

4.1 Single battery unit



4.2 The battery units are connected in parallel

a) 2~4units in parallel connection



Remark:

The "1&2" on the dial resistance of the HV Pack Parallel Box should be turned to the "ON" position, please find the above drawing in red cycle



B) 5~7units in parallel connection

Remark:

The "1&2" on the dial resistance of the HV Pack Parallel Box should be turned to the "ON" position, please find the above drawing in red cycle.

C) 7~10units in parallel connection



Remark:

The "1&2" on the dial resistance of the HV Pack Parallel Box should be turned to the "ON" position, please find the above drawing in red cycle.

5 How to operate Soluna 10K Pack HV (L-E)

Step: please see below information for details.

- 1) Connect the inverter and battery module with communication & battery cable
- Turn on the breaker , the breaker is on the right side of Soluna 10K Pack HV (L-E).

Please see below figure for details.



Remark:

- 1) CAN1 is connected to inverter for communication.
- 2) Soluna 10K Pack HV (L-E) can only operate after receiving the inverter's communication instructions.
- 3) After the system is powered on, the user needs to select the battery

communication protocol on the inverter, so that the system can run normally.

4) In pure off-grid case when the first installation is completed, if there is no PV power, long press the battery black start switch to start the system.

6 LED indicator description

Please find the following table for details.	
--	--

ltem	Color	Description
1	Red	Battery is on black start mode. To active battery black start
		mode, please press the black start button and hold for 10
		seconds. Battery can power the inverter and active the
		communication with inverter if there is no power grid or solar
		panels.
2	Purple	Battery has lost communication with inverter for over 5
		minutes.
3	Yellow	Battery is on protection model. The battery reached to the 3 rd
		level protection alarm such as over voltage, under voltage,
		over temperature, low temperature, etc.
4	White	Battery is on working model. If there are more than one
		battery in parallel connection, it means this battery is the
		master battery on working model.
5	Green	Battery is on working model as a slave battery in parallel
		connection.

7 Trouble shooting guideline

Led Indicator	Possible root cause	How to target the root cause	Solution
Led is purple	1) Compatible inverter	Please check the inverter APP	Update inverter's
	firmware is not the latest	or LCD/LED for firmware	firmware.
	reversion.	reversion.	
	2) Battery firmware is not	Please check the Soluna smart	Update battery's
	the latest reversion.	energy cloud for firmware	firmware.
		reversion.	
	3) Installer didn't choose	Please check if the selection of	Reselect Soluna
	Soluna battery correctly	battery is correct or not.	battery on inverter.
	on inverter APP or		
	LCD/LED.		
	4) Communication cable is	Please check the	Replug or change
	loose or not correct.	communication cable status.	the communication
			cable.
	5) Inverter hardware fault.	Please change another inverter	Contact with inverter
		to try.	manufacture.
	6) Battery hardware fault.	If you checked all the items	Contact with Soluna
		above and still can't target the	for further action.
		reason, please contact with	
		Soluna. Or change the battery.	
N/A	1) Inverter setting incorrect	Check the inverter setting.	Change the inverter
(Battery can't be	such as disable the		setting.
charged or	charging or discharging,		
discharged)	and time setting, etc.		
	2) Inverter can't read Soluna	Please check the battery type	Contact with Inverter
	battery type correctly.	of product and product name	manufacture or
		shown in inverter side.	Soluna for further
			action.
	3) Inverter hardware fault.	Please change another inverter	Contact with Inverter
		to try.	manufacture.
	4) Battery hardware fault.	Please change another battery	Contact with Soluna
		to try.	for further action.
Led is off or	1) Off-grid installation,	Check the battery voltage	Contact with Soluna
yellow	battery can't be charged	through the reserved service	for further action.
	for over 2 weeks due to	port. If the 15K HV voltage is	
	no production of PV	less than 300V, 10K HV	
	system(raining season,	voltage is less than 210V, 6K	
	snow season, or PV	HV voltage is less than 120V,	
	system fault).	please turn off the battery and	
		contact with Soluna.	

Please find the following table for details.

	2) Customer didn't turn off	Check the battery voltage	Contact with Soluna
	the battery for over 2	through the reserved service	for further action.
	weeks in the scenario	port. If the 15K HV voltage is	
	such as:	less than 300V, 10K HV	
	A. Installation is not finished.	voltage is less than 210V, 6K	
	B. System failure, not running.	HV voltage is less than 120V,	
		please turn off the battery and	
		contact with Soluna.	
	3) The battery was stocked	Check the battery voltage	Contact with Soluna
	for over 2 years without	through the reserved service	for further action.
	charging.	port. If the 15K HV voltage is	
		less than 300V, 10K HV	
		voltage is less than 210V, 6K	
		HV voltage is less than 120V,	
		please turn off the battery and	
		contact with Soluna.	
N/A	1) Battery firmware is not	Please check the Soluna smart	Updating the battery
	updated to latest.	energy cloud for battery	firmware to the
		firmware reversion.	latest.
Master battery is	1) Battery communication	Check the communication	Replug or change
white,	cable is loose or not	cable status.	the communication
but not all slaver	correct.		cable.
battery are	2) Battery power cable is	Check the battery power cable.	Fasten the power
green	loose, or not correct		cable.
	connected.		
	3) Communication terminal	Check the parallel box for the	Dail the terminal
	resistor is not dailed or not	resistor dailling.	resistor according to
	dailed correctly.		manual or SOP.
	4) Battery firmware is not the	Please check the Soluna smart	Upgrade the
	latest.	energy cloud for battery	firmware to the
		firmware reversion.	latest.
N/A	1) The Wifi network is not	Check the ender user network	Please choose only
	compatible	type.	2.4G wifi mode.
	2) Connecting fail	APP will remind.	Please read the SOP
			of wifi setting up.
	3) System establish failed	APP will remind.	Contact with Soluna
	due to S/N invalid.		for further action.
N/A	1) Battery reach to 1st level	Please check the Soluna smart	Please ignore it, this
	alarm such as battery over	energy cloud for battery alarm	alarm message is
	voltage.	information.	only used for inverter
			strategy. The power
			of charging/
			discharging will be
			reduced.

	2) Battery reach to 2nd level	Please check the Soluna smart	Please ignore it, this
	alarm such as battery over	energy cloud for battery alarm	alarm message is
	voltage.	information.	only used for inverter
			strategy. The power
			of charging/
			Discharging will be
			limited.
Yellow	1) Battery reach to 3rd level	1) Please check the inverter	Battery will shut
	alarm such as battery over	LCD/LED or APP for the	down, please
	voltage.	battery alarm information.	contact with Soluna
		2) Please check the Soluna	for further action.
		smart energy cloud for	
		battery alarm information.	

8 DOD setting of Inverter

To make sure the battery working smoothly, we recommend the DOD setting of inverter as follows.

On-grid DOD: 80% Off-grid DOD: 70%

9 Contact us

We hope that this user manual has clearly demonstrated the product. If you still have any doubts or something not clear about it in the specifications, feel free contact to us please. we will do our best to support you!

SOLUNA

Add: No.3492 Jinqian Road, Shanghai, China 201406 Tel: +86-21-57475835 Email: sales@solunabattery.com Web: www.solunabattery.com